



Declaration of conformity

Manufacturer VALLOX OY

Address: Myllykyläntie 9 – 11
FIN-32200 Loimaa

Declares that the ventilator **VALLOX 130 E** supply and discharge air, equipped with heat recovery and operating as part of a ventilation system, when designed, installed and serviced according to the instructions given complies with all essential requirements of the following Directives:

- 1. Machine Directive MD (89/392/EEC + 91/368/EEC + 93/44/EEC + 93/68/EEC)**
- 2. Low Voltage Directive LVD (73/23/EEC + 93/68/EEC)**
- 3. EMC (89/336/EEC + 93/68/EEC)**

The sister models of the unit have been tested and inspected in accordance with standard IEC 335-1, as applicable, EN 60 335-1 (1998) + Am.2-6., EN 60 335-2-31 (1990) + A1 (1991) and IEC 324, as well as standards SFS-EN 55014:E (1987), EN 55022 (Class B), EN 61000-3-2 (1995 Class A equipment), IEC EN 61000-3-3 (1995), IEC 801-2 (1991), IEC 801-3 (1984) and IEC 801-4 (1988).

Place and date Loimaa, Finland 9th of March 2001

Rauno Mäkelä
Managing Director